

Memo No:- 141

Date:- 01/03/2024

**Subject : Bacteriological Examination Report of Water Sample**

Sample ID: PKL/04795/2/2024		Sample Details	Date & Time
Sample Classification: Private		Collected By	Parveen garg,9896665463
Sender: Parveen garg28506		Collection Date	23/02/2024 at 11:27
Location :- , DAV SENIOR PUBLIC SCHOOL SURAJPUR, DISTRICT-PANC		Received at lab	23/02/2024 at 11:50
Latitude :- 76.899034 Longitude :- 30.766322		Tested at Lab	01/03/2024

**Test Result (As Per BIS 10500 :2012)**


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PANCHKULA lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



  
SONIA BADESARA,CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING  
LABORATORY PANCHKULA  
email:-chemist.panchkula@phedharyana.gov.in

-----End of Report-----.

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No.

Dated:

It is certified that an inspection team headed by Ms. Sonia Badesara, Chemist  
(Name of Officers with designation) from Distt. Water Testing Lab, Pk. PHED

Inspected the **DAV Senior Public School, Surajpur**

(Name & Address of the school) on 23/02/24 (date of inspection) and on the basis of  
Water Test Report (Attached) bearing no. 141 dated 01/03/24  
of Distt. Water Testing Lab, Pk. (PHED Lab) certified that the

**DAV Senior Public School, Surajpur** ( Name of school) has safe drinking water facilities for the  
students and members of staff of the institution. School is also maintains the hygienic sanitation  
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T.  
Govt.

This certificate is valid till .....

Sonia  
CHEMIST (HSC-II)  
P.H.E.D. LAB.  
PANCHKULA

Signature with Seal: .....  
Name : Ms. Sonia Badesara  
Designation : Chemist  
Name & Address of the Office/Department: .....

PHED District Water Testing  
Laboratory, Panchkula.

To DAV Senior Public School,  
Surajpur, (Panchkula)  
(Name & Address of the Institution)

**Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies**